

**THE ELE**  
APPROVED  
CONTRACTOR

CRN/

TYPE OF INSTALLATION

Contractor's Reference Number

# ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZX

This certificate is not valid if the serial number has been defaced or altered

DCN8/ 0393663

Client and address

MR Danny Dacester

Tick appropriate box

Domestic dwelling ☒ Highway installation ☐

Leisure Accommodation Vehicle ☐

Modular dwelling ☐

Transportable unit ☐

DETAILS OF THE INSTALLATION

Extent of the installation work covered by this certificate

Installation of new consumer unit only

Postcode

Postcode GU22 2AT

ADDRESS OF THE INSTALLATION/LOCATION

Installation address

17 craster Rd  
London

The installation is  
New ☒  
An addition ☐  
An alteration ☐

DESIGN, CONSTRUCTION, INSPECTION AND TESTING

I, being the person responsible for the design, construction, inspection and testing of the electrical installation (as indicated by my signature adjacent), particulars of which are described above, having exercised reasonable skill and care when carrying out the design, construction, inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671, amended to (date) except for the departures, if any, detailed as follows:

Relevant risk assessment(s) have been attached to this certificate (Regulation 411.3.3 indent (a)) ☐

The extent of liability of the signatory is limited to the work described above as the subject of this certificate. For the DESIGN, the CONSTRUCTION and the INSPECTION AND TESTING of the installation

Signature

P. C. Thomas

Name (CAPITALS)

P. THOMAS

Date

5/6/18

Signature

P. C. Thomas

Name (CAPITALS)

P. THOMAS

Date

5/6/18

The results of the inspection and testing reviewed by the Qualified Supervisor

NEXT INSPECTION

5 Enter interval in terms of years, months or weeks as appropriate

I RECOMMEND that this installation is further inspected and tested after an interval of not more than 5 years

COMMENTS ON EXISTING INSTALLATION

Note: Enter NONE or, where appropriate, the page number(s) of additional page(s) of comments on the existing installation

More sockets needed in bedrooms

SCHEDULE OF ADDITIONAL RECORDS\*

See attached schedule

In the case of an alteration or additions see Section 623 of BS 7671



Address

Trading title  
North Heath Electrical Services (NS) Ltd  
Hilborne  
London Rd  
Wrotham  
Kent

Telephone No

01438 74

NICEIC Enrolment No

043874

Branch No (if applicable)

Postcode TN15 7ET

Where the electrical work to which this certificate relates includes the installation of a fire detection/alarm system (or a part of such a system), this electrical safety certificate should be accompanied by the particular certificate for the system, issued by Censure LLP. Censure LLP operates the ELECSA & NICEIC brands. © Copyright Censure LLP

Please see the 'Notes for Recipients' on the reverse of this page.

**This certificate is not valid  
if the serial number has  
been defaced or altered**

DCN8/ 0393663

**Original** (To the person ordering the work)

Main Switch/Switch-Fuse/Circuit-Breaker/RCD	
Type (BSEN)	Voltage rating
60947-3	230 V
No of poles	Rated current, $I_n$
2	100 A
Supply conductors material	RCD operating current, $I_{\Delta n}$
copper	30 mA
Supply conductors CSA	RCD operating time (at $I_{\Delta n}$ )
25 mm <sup>2</sup>	0.4 ms
	Rated time delay
	0.4 ms

\* applicable only where an RCD is used as a main circuit-breaker

## Earthing and protective bonding conductors

Page 2 of 2

DCN8/3

# ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

† See note below

## SCHEDULE OF ITEMS INSPECTED

### 1.0 CONDITION/ADEQUACY OF DISTRIBUTOR'S/SUPPLY INTAKE EQUIPMENT (the Distributor should be notified of any unsatisfactory equipment)

1.1	Service cable	✓
1.2	Distributor's earthing arrangement	✓
1.3	Meter tails - Distributor/Consumer	✓
1.4	Metering equipment	✓
1.5	Means of main isolation (where present)	✓

### 2.0 PARALLEL OR SWITCHED ALTERNATIVE SOURCES OF SUPPLY

2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A
2.3	Presence of alternative/additional supply warning notice(s)	✓

### 3.0 AUTOMATIC DISCONNECTION OF SUPPLY

3.1	Presence and adequacy of protective earthing/bonding arrangements as follows:	
a)	Distributor's earthing arrangement or installation earth electrode arrangement	N/A
b)	Earthing conductor and connections	✓
c)	Main protective bonding conductors and connections	✓
d)	Earthing/bonding labels at all appropriate locations	N/A

### 3.2 Accessibility of:

a)	Earthing conductor connections	✓
b)	All protective bonding connections	✓

### 4.0 BASIC PROTECTION

4.1	Presence and adequacy of measures to provide basic protection (prevention of contact with live parts) within the installation:	
a)	Insulation of live parts e.g. conductors completely covered with durable insulating materials	✓
b)	Barriers or enclosures e.g. correct IP rating	✓

### 5.0 ADDITIONAL PROTECTION

5.1	Presence and effectiveness of additional protection methods	
a)	RCD(s) not exceeding 30 mA operating current	✓
b)	Supplementary bonding	✓
c)	Segregation of safety circuits	✓

### 6.0 OTHER METHODS OF PROTECTION

6.1	Basic and fault protection	✓
a)	SELV	✓
b)	PELV	✓
c)	Double insulation/Reinforced insulation	✓
d)	Electrical separation for one item of equipment	✓
6.2	Presence of danger notices	✓

### 7.0 SWITCHGEAR/CONSUMER UNIT(S)

7.1	Adequacy of working space/accessibility	✓
7.2	Security of fixing	✓
7.3	Adequacy/security of barriers	✓
7.4	Insulation of live parts not damaged during erection	✓
7.5	Enclosures not damaged during installation	✓
7.6	Suitability of enclosures for IP and fire ratings	✓
7.7	Presence and operation of main switch(es), linked, where appropriate to verify disconnection	✓
7.8	Switchgear not damaged/deteriorated such as might impair safety	✓
7.9	Operation of circuit-breakers and RCDs to prove functionality	✓
7.10	Correct identification of circuit protective devices	✓
7.11	RCD(s) provided for fault protection, where specified	✓
7.12	RCD(s) provided for additional protection, where specified	✓
7.13	Confirmation of overvoltage protection (SPDs) provided and functional where specified	N/A
7.14	Presence of RCD quarterly test notice at or near the origin	✓
7.15	Presence of diagrams, charts or schedules at or near each Consumer unit(s)	✓
7.16	Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required	✓
7.17	Presence of next inspection recommendation label	✓
7.18	Presence of other required labelling	✓
7.19	Selection of protective device(s) and base(s); correct type and rating	N/A
7.20	Single-pole protective devices in line conductor only	✓
7.21	Protection against mechanical damage where cables enter equipment	✓
7.22	Protection against electromagnetic effects where cables enter ferromagnetic enclosures	✓
7.23	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	✓

### 8.0 CIRCUITS

8.1	Identification of conductors	✓
8.2	Cables adequately supported throughout their length	✓
8.3	Examination of cables for signs of mechanical damage during installation	✓
8.4	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓
8.5	Adequacy of protective devices: type and rated current for fault protection	✓
8.6	Presence and adequacy of circuit protective conductors	✓
8.7	Coordination between conductors and overhead protective devices	✓
8.8	Non-sheathed cables enclosed throughout (e.g. in conduit/trunking)	✓
8.9	Cables installed under floors, above ceilings, in walls/partitions, adequately protected against damage	✓
a)	Installed in prescribed zones	✓
b)	Incorporating earthed armour or sheath, or installed within earthed wiring system, or otherwise protected against mechanical damage by nails, screws and the like	✓

† All boxes must be completed. '✓' indicates that an inspection was carried out and that the result was satisfactory. 'N/A' indicates that an inspection was not applicable to the particular installation.

‡ Where a smoke alarm has been installed, separate certification is required on the appropriate form.

This certificate is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICIC brands. © Copyright Certsure LLP (July 2015)

# ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

<sup>†</sup> See note below

## SCHEDULE OF ITEMS INSPECTED continued

8.10	Provision of additional protection by RCDs having rated residual operating current ( $I_{\Delta n}$ ) not exceeding 30 mA	
a)	For mobile equipment with a current rating not exceeding 32 A for use outdoors	✓
b)	For all socket-outlets of rating 20 A or less, unless exempt	✓
c)	For cables installed in walls/partitions at a depth of less than 50 mm	✓
d)	For cables installed in walls/partitions containing metal parts regardless of depth	✓
8.11	Provision of fire barriers, sealing arrangements so as to minimise the spread of fire	✓
8.12	Band II cables segregated/separated from Band I cables	✓
8.13	Cables segregated/separated from non-electrical services	✓
8.14	Termination of cables at enclosures	✓
a)	Connections under no undue strain	✓
b)	No basic insulation of a conductor visible outside enclosure	✓
8.15	Circuit accessories not damaged during erection	✓
8.16	Single-pole devices for switching or protection in the line conductors only	✓
8.17	Adequacy of connections, including spcs, within accessories and at fixed and stationary equipment	✓
8.18	Presence of appropriate devices for isolation and switching correctly located	✓
a)	Accessible means of switching off for mechanical maintenance	✓
b)	Correct operation verified (functional check)	✓
8.19	Cables incorporating earthed armour or sheath or run in an earthed wiring system, or otherwise protected against nails, screws and the like	✓

## SCHEDULE OF ITEMS INSPECTED PARTICULAR TO A LEISURE ACCOMMODATION VEHICLE OR TRANSPORTABLE UNIT

1.	Cables adequately protected against the effects of vibration	
2.	Presence of protection against mechanical damage where cables enter equipment	
3.	Cables segregated/separated from non-electrical services such as LPG compartment (see Regulation 721.528.3.4)	
4.	Accessories/Equipment	
-	Security of fixing, and suitability for the environment and external influences (e.g. IP rating)	
-	Equipment does not constitute a fire hazard	

## 9.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)

9.1	Adequacy of working space/accessibility	✓
9.2	Suitability of equipment in terms of IP and fire ratings	✓
9.3	Enclosure not damaged/deteriorated during installation so as to impair safety	✓
9.4	Cable entry holes in ceilings above luminaires, sized or sealed so as to restrict the spread of fire	✓
9.5	Recessed luminaires (downlighters)	✓
a)	Correct type of lamps fitted	✓
b)	Installed to minimise build-up of heat	✓

## 10.0 LOCATION(S) CONTAINING A BATH OR SHOWER

10.1	Additional protection by RCD not exceeding 30 mA	
a)	For low voltage circuits serving the location	✓
b)	For low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✓
10.2	Where used as a protective measure, requirements for SELV or PELV are met	✓
10.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535	24/17 ✓
10.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓
10.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	✓
10.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓
10.7	Suitability of electrical equipment for installation in a particular zone	✓

## 11.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS

11.1	List all other special installations or locations present, if any. (Record separately where the result of particular inspections apply)	
------	---	--

## SCHEDULE OF ITEMS INSPECTED PARTICULAR TO HIGHWAY STREET FURNITURE

1.	The requirements of BS 7671 regarding access to live parts (see Regulation 714.411.2.201) have been met.	
2.	Enclosure(s) securely fixed and not damaged/deteriorated so as to impair safety	
3.	Presence of protection against mechanical damage where cables enter equipment	
4.	Provision of RCD of $I_{\Delta n} \leq 30$ mA for additional protection for lighting of bus shelters, telephone kiosks, town plans and the like	
5.	Connection of conductors adequately enclosed	
6.	Accessories/Equipment	
-	Security of fixing, and suitability for the environment and external influences (e.g. IP rating)	
-	Equipment does not constitute a fire hazard	

## SCHEDULE OF ITEMS INSPECTED BY:

Signature *P. C. Thomas* Name (Capital): *P. C. THOMAS*

Date: *5/6/18*



APPROVED  
CONTRACTOR

ELECTRICAL INSTALLATION CERTIFICATE FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

This certificate is not valid  
if the serial number has  
been defaced or altered

DCN8/ 0393663

CIRCUIT DETAILS

TEST RESULTS

Circuit number	Circuit designation	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa		Max. disconnection time permitted by BS 7671 (s)	Overcurrent protective devices			RCD	Circuit impedances				Insulation resistance				Polarity	Maximum measured earth fault loop impedance Z <sub>s</sub>	RCD		Test button operation				
*	RCD				Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	(2) Ring final circuits only (measured end to end)			All circuits (At least one column to be completed)		Unline (MΩ)	Unl/Neutral (MΩ)	Unl/Earth (MΩ)	Neutral/Earth (MΩ)	(✓)	(Ω)	at I <sub>Δn</sub> (ms)	at 5 I <sub>Δn</sub> (if applicable) (ms)	(✓)	
															r <sub>1</sub> (line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (cpc)	R <sub>1</sub> + R <sub>2</sub>	R <sub>2</sub>									
1	Kitchen sockets	A	A	10	2.5	1.5	0.4	608018	B32	6			1.08	0.41	0.41	0.65	0.26		N/A	Zero	Zero	Zero	✓	0.35				
2	1 <sup>st</sup> Floor Sockets	A	A	6	2.5	1.5	0.4	..	B32	6			1.08	0.31	0.31	0.44	0.15		N/A	..	..	..	✓	0.56				
3	Basement lights	A	A	3	1.5	1.0	0.4	..	B6	6			6.82			0.35		N/A	..	..	..	✓	0.40					
	RCD							61008	80			30												36	20	✓		
8	Ground Floor Sockets	A	A	5	2.5	1.5	0.4	608018	B32	6			1.08	0.13	0.13	0.29	0.25		N/A	Zero	Zero	Zero	✓	0.35				
9	lights	A	A	18	1.5	1.0	0.4	..	B6	6			5.82			0.98		N/A	..	..	..	✓	1.08					

Location of consumer unit	under stairs	Designation of consumer unit	Power Lights	Prospective fault current at consumer unit	2.8	kA
---------------------------	--------------	------------------------------	--------------	---	-----	----

TEST INSTRUMENTS				Test instruments (serial numbers) used			
Multifunction	8726840	Insulation resistance		Continuity		Earth electrode resistance	
						Earth fault loop impedance	
						RCD	

CODES FOR TYPE OF WIRING

A	B	C	D	E	F	G	H	O (Other - please state)
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in non-metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic/SWA cables	Thermosetting/SWA cables	Mineral-insulated cables	

Original (To the person ordering the work)



APPROVED  
CONTRACTOR

Contractor's Reference Number

CRN/

Issued in accordance with British Standard 7671 - Requirements for Electrical Installations by an Approved Contractor or Conforming Body enrolled with NICEIC, Warwick House, Houghton Hall Park, Houghton Regis, Dunstable LU5 5ZK.

TYPE OF INSTALLATION

Tick appropriate box

Domestic dwelling



Highway Installation

Leisure Accommodation Vehicle



Modular dwelling



Transportable unit

DETAILS OF THE CLIENT

Client:

MR Danny Da Costa

Address:

Postcode:

PURPOSE OF THE REPORT

Purpose for which this report is required:

Annual Safety Check

Date(s) on which inspection and testing were carried out:

31/05/18

DETAILS OF THE INSTALLATION

Occupier:

Address:

17 Grafton Road  
Barton Hill  
SW2 2AF

Postcode:

Estimated age of the electrical installation:

30 years

Evidence of alterations or additions

Yes

If yes, estimated age

7

Date of previous inspection:

N/A

Electrical Installation Certificate No or previous Periodic Inspection or Condition Report No:

Records of installation available:

Records held by:

## ELECTRICAL INSTALLATION CONDITION REPORT

FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

This report is not valid if the serial number has been defaced or altered

DPN7/

0216502

EXTENT OF THE INSTALLATION AND LIMITATIONS ON THE INSPECTION AND TESTING

Extent of the electrical installation covered by this report:

Whole

Agreed limitations including the reasons, if any, on the inspection and testing:

None

Agreed with:

Operational limitations including the reasons (see page No. 1)

unable to check joints and junctions that may be in walls or under floors.

The inspection and testing have been carried out in accordance with BS 7671, as amended. Cables concealed within trunking and conduits, or cables and conduits concealed under floors, in inaccessible roof spaces and generally within the fabric of the building or underground, have not been visually inspected unless specifically agreed between the client and inspector prior to the inspection.

SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety):

This installation is now in a safe condition to be in service as all observations and recommendations have been sorted.

Summary of the condition of the installation continued on additional pages? No Yes Specify page No(s):

Overall assessment of the installation:

SATISFACTORY / UNSATISFACTORY\*

Delete as appropriate

\* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that Further investigation without delay (F1) is required

This report should have been reviewed and confirmed by the registered Qualified Supervisor of the Approved Contractor responsible for issuing it. (See declaration on page 2)

This report is based on the model forms shown in Appendix 6 of BS 7671.

Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (July 2015)

Original (To the person ordering the work)

**This report is not valid if the serial number has been defaced or altered**

0216502

## DECLARATION

There are **no** items adversely affecting electrical safety

**or** The following observations and recommendations for action are made

Code +

I/We further declare that in my/our judgement, the overall assessment of the installation in terms of its suitability for continued use is **SATISFACTORY / UNSATISFACTORY\*** *Delete as appropriate*

at the time the inspection was carried out, and that it should be further inspected as recommended within the time interval given below.

\* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that further investigation without delay (FI) is required

**INSPECTION, TESTING AND ASSESSMENT BY:**

Signature: *PC Phoenix*

Name: *P. C. Phoenix*

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described on page 1, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent of the installation and the limitations on the inspection and testing.

I/We further declare that in my/our judgement, the overall assessment of the installation in terms of its suitability for continued use is **SATISFACTORY / UNSATISFACTORY\*** *Delete as appropriate*

at the time the inspection was carried out, and that it should be further inspected as recommended within the time interval given below.

I/We further declare that in my/our judgement, the overall assessment of the installation in terms of its suitability for continued use is **SATISFACTORY / UNSATISFACTORY\*\*** *Delete as appropriate*

at the time the inspection was carried out, and that it should be further inspected as recommended within the time interval given below.

\* An 'Unsatisfactory' assessment indicates that dangerous (CODE C1) and/or potentially dangerous (CODE C2) conditions have been identified, or that further investigation without delay (FI) is required

## INSPECTION, TESTING AND ASSESSMENT BY:

Signature: 

Name: P. Tennant  
(CAPITALS)

Position:

Supervising Engineer

Date: 3/1/18

REPORT REVIEWED AND CONFIRMED BY:

Signature: \_\_\_\_\_

P. C. Thomas

Name:  
(CAPITALS)

P. Thompson  
(Registered Qualified Supervisor)

Date:

7/6/18

## NEXT INSPECTION

I/We recommend that this installation is further inspected and tested after an interval of not more than:

5 years

(Enter interval in terms of years or months, as appropriate)

Additional pages?	No	Yes	Specify page No(s):
† One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action:			

**Immediate remedial action required for items:**

**Urgent remedial action  
required for items:**

 $2, 3, 4, 5$ 

**Code C1** 'Danger present'. Risk of injury. Immediate remedial action required.

**Further investigation required without delay for items:**

6

Code C3 'Improvement recommended'.

**Improvement  
recommended for items:**

17

**Code F1** *'Further investigation required without delay.'*  
Please see the reverse of this page for guidance regarding the Classification codes.

Please see the 'Guidance for Recipients on the Classification codes' on the reverse of this page.

Page 2 of 2

**Original** (To the person ordering the work)

# ELECTRICAL INSTALLATION CONDITION REPORT FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

**This report is not valid if the serial number has been defaced or altered**

DPN7/ 0216502

**Original** (To the person ordering the work)

SUPPLY CHARACTERISTICS				Tick boxes and enter details, as appropriate				Notes: (1) by enquiry (2) by enquiry or by measurement (3) where more than one supply, record the higher or highest values (4) by measurement				Characteristics of primary supply overcurrent protective devices)			
System type(s)		Number and type of live conductors		Nature of supply parameters											
TN-S	<input checked="" type="checkbox"/>	1-phase (2-wire)	<input checked="" type="checkbox"/>	Number of sources	1	Nominal voltage(s)	U <sup>(1)</sup>	V	Nominal frequency, f <sup>(1)</sup>	50	Hz	BS(EN)	1361		
TN-C-S	<input type="checkbox"/>	3-phase (3-wire)	<input type="checkbox"/>	U <sup>(1)</sup>	230	V	External earth fault loop impedance, Z <sub>e</sub> <sup>(3/4)</sup>	<input type="checkbox"/>	$\Omega$	Type	ITB	Confirmation of supply polarity	<input checked="" type="checkbox"/>		
TT	<input type="checkbox"/>	Other	<input type="checkbox"/>	Single-phase Prospective fault current, I <sub>pf</sub> <sup>(2/3)</sup>	2.6	kA	3-phase Prospective fault current, I <sub>pf</sub> <sup>(2/3)</sup>	<input type="checkbox"/>	kA	Rated current	60	A			

PARTICULARS OF INSTALLATION AT THE ORIGIN										Tick boxes and enter details, as appropriate	
Means of earthing			Details of installation earth electrode (where applicable)				Measured $Z_e$				
Distributor's facility	✓	Type (eg rod(s), tape etc)	Location	Method of measurement	Protective measure(s) for fault protection	Maximum demand (Load)	Number of smoke alarms	kVA/ Amps	Delete as appropriate		
Installation earth electrode		Electrode resistance, $R_a$	$\Omega$								
Earthing conductor											
Conductor material	Copper	Continuity/ connection verified	✓	Conductor material	Copper	Conductor csa	16	mm <sup>2</sup>	Water installation pipes	✓	
Conductor csa	16	mm <sup>2</sup>		Location (where not obvious)		Oil installation pipes	Other		Structural steel	Other	
						Gas installation pipes					
Main protective bonding conductors and bonding of extraneous-conductive-parts											
Supply conductors material	Copper	RCD operating current, $I_{\Delta n}$	20	mm <sup>2</sup>	RCD operating time (at $I_{\Delta n}$ )	20	ms	Rated time delay	20	ms	
Supply conductors csa	25	mm <sup>2</sup>									

\* applicable only where an RCD is used as a main circuit-breaker

VEHICLE DETAILS							
Type:	Touring	Satellite Motorhome	Year of manufacture	Model	Registration (motorhome)		
VIN							
<i>Tick boxes and enter details as appropriate</i>							
PARTICULARS OF VEHICLE INSTALLATION OR TRANSPORTABLE UNITS							
<input type="checkbox"/> Hook-up connection Flexible supply cable		<input type="checkbox"/> System type: TT		<b>Means of earthing</b>			
		<b>For direct connection</b> Installation earth electrode details:  Type(e.g. rod(s), tape(s))  Electrode resistance, R <sub>a</sub>  Location		System type: TN-S <input type="checkbox"/> TN-C-S* <input type="checkbox"/> * Connection to a TN-C-S system requires supervision (see regulation 717.411.4)  Measured earth fault loop impedance, Z <sub>e</sub>  			
Length  L <sub>s</sub>	m  A	dcsa  R <sub>i</sub> +Z <sub>p</sub> /csc  Ω	mm²  Ω	Method of measurement			
<b>Supply voltage(s) and maximum load/demand</b>			Nominal voltage(s)  U <sub>o</sub>	U	Maximum permitted load	kVA/ Amps	
TRANSPORTABLE UNIT DETAILS							
Description							
<b>Earthing and protective bonding conductors</b> Tick boxes and enter details as appropriate							
Earthling conductor (for static vehicles or transportable units)				Conductor material			
Chassis				Conductor material			
Water service				Conductor verified			
Gas service				Conductor csa			
				Connection continuity verified			
				Connection/continuity verified			
				Connection/continuity verified			

<sup>†</sup> All boxes must be completed. '✓' indicates that an inspection was carried out and that the result was satisfactory. 'N/A' indicates that an inspection was not applicable to the particular installation.

This certificate is based on the model forms shown in Appendix 6 of BS 7671. Published by Certsure LLP. Certsure LLP operates the ELECSA & NICEIC brands. © Copyright Certsure LLP (July 2015)

**DETAILS OF NICEIC APPROVED CONTRACTOR**

Trading title: **Karlheath Electrical Services (AG) Ltd**  
Address: **Atldene, London Rd, Kent**

Postcode: **TN15 7RS**

Enrolment number: **043874**  
Branch number: **(if applicable)**  
Telephone number: **07945693935**  
Email address:

**SCHEDULE OF INSPECTIONS**

Item	Description	Outcome*	Item	Description	Outcome*	Item	Description	Outcome*
1.0	Condition/adequacy of distributor/supply intake equipment†		4.0	Consumer unit(s)		4.23	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure	
1.1	Service cable	✓	4.1	Adequacy of working space or access to consumer unit	✓	5.0	Distribution/final circuits	
1.2	Service head	✓	4.2	Security of fixing	✓	5.1	Identification of conductors	C3
1.3	Distributor's earthing arrangement	✓	4.3	Condition of enclosure(s) in terms of IP rating	✓	5.2	Cables correctly supported throughout their length	LW
1.4	Meter tails - Distributor/Consumer	✓	4.4	Condition of enclosure(s) in terms of fire rating	C3	5.3	Condition of insulation of live parts	✓
1.5	Metering equipment	✓	4.5	Enclosure not damaged/deteriorated so as to impair safety	✓	5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (including confirmation of the integrity of conduit and trunking systems)	✓
1.6	Means of main isolation (where present)	✓	4.6	Presence of linked main switch	✓	5.5	Adequacy of cables for current-carrying capacity with regard to the type and nature of installation	✓
2.0	Presence of adequate arrangements for other sources (microgenerators etc)		4.7	Operation of main switch (functional check)	✓	5.6	Adequacy of protective devices; type and rated current for fault protection	C2
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply	N/A	4.8	Main switch capable of being secured in the OFF position	C3	5.7	Presence and adequacy of circuit protective conductors	✓
2.2	Adequate arrangements where a generating set operates in parallel with the public supply	N/A	4.9	Operation of circuit-breakers and RCDs to prove disconnection (functional check)	C2	5.8	Co-ordination between conductors and overload protective devices	✓
2.3	Presence of alternative/additional supply warning notice(s)	N/A	4.10	Correct identification of circuits and protective devices	✓	5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences	✓
3.0	Earthing and bonding arrangements		4.11	Presence of RCD test notice at or near consumer unit	N/A	5.10	Cables installed under floors, above ceilings, in walls / partitions, adequately protected against damage	LW
3.1	Presence and condition of distributor's earthing arrangement	✓	4.12	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit	C3			
3.2	Presence and condition of earth electrode connection	N/A	4.13	Presence of alternative or additional supply warning notice at or near consumer unit	N/A			
3.3	Confirmation of adequate earthing conductor size	✓	4.14	Presence of next inspection recommendation label	C3			
3.4	Accessibility and condition of earthing conductor at Main Earthing Terminal (MET)	✓	4.15	Presence of other required labelling (please specify)	N/A			
3.5	Confirmation of adequate main protective bonding conductor sizes	✓	4.16	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)	C2			
3.6	Accessibility and condition of main protective bonding conductor connections	✓	4.17	Single-pole switching or protective devices in the line conductors only	✓			
3.7	Accessibility and condition of other protective bonding connections	✓	4.18	Protection against mechanical damage where cables enter consumer unit	✓	5.11	Provision of additional protection by RCD not exceeding 30 mA	C2
3.8	Provision of earthing and bonding labels at all appropriate locations	✓	4.19	Protection against electromagnetic effects where cables enter metallic consumer unit/enclosure	✓			
			4.20	RCDs provided for fault protection – includes RCBOs	C2			
			4.21	RCDs provided for additional protection – includes RCBOs	C2			
			4.22	Confirmation of indication that SPD is functional	N/A			

† Where inadequacies in distributor's equipment are encountered, it is recommended that the person ordering the report informs the appropriate authority.  
‡ Older installations designed prior to BS 7671: 2008 may not have been provided with RCDs for additional protection.

ELECTRICAL INSTALLATION CONDITION REPORT FOR SMALL INSTALLATIONS NOT EXCEEDING 100 A

This report is not valid  
if the serial number has  
been defaced or altered

DPN7/ 0216502

SCHEDULE OF INSPECTIONS

Item	Description	Outcome*	Item	Description	Outcome*	Item	Description	Outcome*
5.12	Provision of fire barriers, sealing arrangements and protection against thermal effects	✓	7.0	Current-using equipment (Permanently connected)		9.0	Other special installations or locations - Part 7s	
5.13	Band II cables segregated/separated from Band I cables	✓	7.1	Condition of equipment in terms of IP rating		9.1	List of all other special installations or locations, if any, present. (Record the results of any particular inspection and append separately).	✓
5.14	Cables segregated/separated from communications cabling	✓	7.2	Equipment does not constitute a fire hazard	✓			
5.15	Cables segregated/separated from non-electrical services	✓	7.3	Enclosure not damaged/deteriorated so as to impair safety	✓			
5.16	Termination of cables at enclosures (extent of sampling indicated on page 1 of the report)	✓	7.4	Suitability for the environment and external influences	✓			
	• Connections soundly made and under no undue strain	✓	7.5	Security of fixing	✓			
	• No basic insulation of a conductor visible outside enclosures	✓	7.6	Cable entry holes in ceiling above luminaires, sized or sealed so as to restrict the spread of fire	✓			
	• Connections of live conductors adequately enclosed (glands, bushes etc.)	✓		List number and location of luminaires inspected. (Separate page)	✓			
5.17	Condition of accessories including socket-outlets, switches and joint boxes	✓	7.7	Recessed luminaires (downlighters)	✓			
5.18	Suitability of accessories for external influences	✓		• correct type of lamps fitted	✓			
5.19	Adequacy of working space / accessibility to equipment	✓		• installed to minimise build-up of heat by use of 'fire rated' fittings,	✓			
5.20	Single-pole devices for switching or protection in line conductors only	✓		• insulation displacement box or similar	✓			
				• no signs of overheating to surrounding building fabric	✓			
6.0	Isolation and switching (isolation, switching off for mechanical maintenance and functional switching)		8.0	Location(s) containing a bath or shower				
6.1	In general	✓	8.1	Additional protection by RCD not exceeding 30 mA	✓			
	• presence and condition of appropriate devices	✓		• for low voltage circuits serving the location	✓			
6.2	For isolation and switching for mechanical maintenance only	✓		• for low voltage circuits passing through Zone 1 and Zone 2 not serving the location	✓			
	• capable of being secured in the OFF position where appropriate	✓	8.2	Where used as a protective measure, requirements for SELV or PELV are met	✓			
	• acceptable location – state if local or remote from equipment being controlled where appropriate	✓	8.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3353	✓			
	• clearly identified by position and/or durable marking(s)	✓	8.4	Presence of supplementary bonding conductors unless not required by BS 7671: 2008	✓			
6.3	For isolation only	✓	8.5	Low voltage (e.g. 230 volts) socket-outlets sited at least 3 m from zone 1	✓			
	• warning label(s) posted in situations where live parts cannot be isolated by the operation of a single device	✓	8.6	Suitability of equipment for external influences for installed location in terms of IP rating	✓			
			8.7	Suitability of equipment for installation in a particular zone	✓			

5 Note: Older installations designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection

SCHEDULE OF ITEMS INSPECTED PARTICULAR TO A LEISURE ACCOMMODATION VEHICLE OR A TRANSPORTABLE UNIT

Item	Description	Outcome*
10.0	Means of connection	
10.1	'Hook-up' connection arrangement (inlet, plug and connector)	
	• equipment complies with BS EN 60309-2	
10.2	Flexible 'hook-up' cable	
	• acceptable condition	
	• correct length and size (csa)	
10.3	Acceptable type (to BS 7919) and condition	
	• direct connection (to specific vehicles)	
	• acceptable type of wiring system and condition	
	• correct size (csa)	
10.4	Presence of required identification/labelling	
	• instructions for the safe use of the caravan/transportable unit installation/supply	
	• indication of voltage (stated on or adjacent) to all extra-low voltage (ELV) socket-outlets	
10.5	Plugs and socket-outlets non-interchangeable with those of LV installation	
10.6	All conductors adequately protected against mechanical damage	
10.7	All conductors adequately protected against mechanical stresses (e.g. vibration from vehicular motion)	

SCHEDULES AND ADDITIONAL PAGES

Schedule of Inspections:	Page(s) No 4, 5	Additional pages, including data sheets for additional source(s):	Page No(s)	Schedule of Circuit Details for the Installation:	Page No(s)	6
Special installations or locations:	Page No(s)	The pages identified are an essential part of this report. The report is valid only if accompanied by all the schedules and additional pages identified above.		Schedule of Test Results for the Installation:	Page No(s)	6

\* All boxes must be completed. ✓ indicates Acceptable condition. N/A indicates Not applicable. Further investigation required without delay state FI (to determine whether danger or potential danger exists). C1, C2, C3 and FI coded items to be recorded in Page 2 of the report.

**CIRCUIT DETAILS**

**TEST RESULTS**

Circuit number	Circuit designation <small>* To be completed only where this consumer unit is remote from the origin of the installation. Record details of the circuit supplying this consumer unit in the bold box.</small>	Type of wiring (see code)	Reference method (see Appendix 4 of BS 7671)	Number of points served	Circuit conductors: csa		Max. disconnection time permitted by BS 7671 (s)	Overcurrent protective devices			RCD	Circuit impedances (Ω)			Insulation resistance				Polarity	Maximum measured earth fault loop impedance, Z <sub>s</sub> (Ω)	RCD		Test button operation				
*					Live (mm <sup>2</sup> )	CPC (mm <sup>2</sup> )		BS (EN)	Type	Rating (A)	Short-circuit capacity (kA)	Operating current, I <sub>Δn</sub> (mA)	Maximum Z <sub>s</sub> permitted by BS 7671 (Ω)	r <sub>1</sub> (line)	r <sub>n</sub> (Neutral)	r <sub>2</sub> (CPC)	All circuits (At least one column to be completed)	Line/Line (MΩ)	Line/Neutral (MΩ)	Line/Earth (MΩ)	Neutral/Earth (MΩ)	(✓)	(s)	at I <sub>Δn</sub> (ms)	at 5 I <sub>Δn</sub> (typical) (ms)	(✓)	
1	Socket of	A	A	6	2.5	1.5	0.4	3036	1	30	10	N/A	0.83	0.31	0.31	0.47	0.46	N/A	>2000	>2000	>2000	>2000	✓	0.56	N/A	N/A	
2	Socket Down	A	A	4	2.5	1.5	0.4	3036	1	30	10	N/A	0.83	0.13	0.12	0.29	0.25	N/A	>2000	>2000	>2000	>2000	✓	0.35	N/A	N/A	
3	Down lights	A	A	18	1.5	1.0	0.4	3036	1	15	10	N/A	1.93	N/A	N/A	N/A	N/A	N/A	>2000	>2000	>2000	>2000	✓	0.40	N/A	N/A	
4	Basement lights	A	A	3	1.5	1.0	0.4	3036	1	5	10	N/A	1.94	N/A	N/A	N/A	0.30	N/A	>2000	>2000	>2000	>2000	✓	0.40	N/A	N/A	
5	Auxiliary Board																										
6	Kitchen Sockets	A	A	11	2.5	1.5	0.4	3036	1	30	10	N/A	0.83	0.41	0.41	0.65	0.25	N/A	>2000	>2000	>2000	>2000	✓	0.35	N/A	N/A	
7																											
8																											
9																											
10																											
11																											
12																											
13																											
14																											
15																											
16																											
17																											
18																											
19																											
20																											

Location of consumer unit **Under Stairs**

Designation of consumer unit **Power / Lights**

Prospective fault current at consumer unit **2.6** **KA**

**TEST INSTRUMENTS**

Test instruments (serial numbers) used

Multi-function **6226840**

Insulation resistance

Continuity

Earth electrode resistance

Earth fault loop impedance

RCD

**CODES FOR TYPE OF WIRING**

A	B	C	D	E	F	G	H	0 (Other - please state)
Thermoplastic insulated/sheathed cables	Thermoplastic cables in metallic conduit	Thermoplastic cables in metallic conduit	Thermoplastic cables in metallic trunking	Thermoplastic cables in non-metallic trunking	Thermoplastic/SWA cables	Thermosetting/SWA cables	Mineral-insulated cables	

Original (To the person ordering the work)